



ଓଡ଼ିଶା ସରକାର

**OFFICE OF THE SUPERINTENDING ENGINEER
KALAHANDI (R&B) DIVISION, BHAWANIPATNA**

Letter No. 1896 // Date. 17.3.22 //

To

The Secretary
Pragati Concept School,
Pragati Trust,
Bhawanipatna

Sub: - Issue of Building safety certificate in favor of Pragati Concept School for the year 2022-2023.

Ref:- Your letter No.66 Dated 16.02.2022.

Sir,

With reference to the subject cited above It is to state that the Pragati Concept School at Bhawanipatna is located on plot no 107/585, 107/651 and 107/650 and Khata no 89/256, Mouza- Raisingpur. This building construction is completed in the year 2021. The following observation were noted.

- It is found that the said building is (G + 3) storied RCC Framed structure.
- The structural components of building i.e. Roof, Columns, Beams, walls and floors etc of said building are in good condition.
- The Total built up area is 41920 Sft. The total break up .area is as follows. (GF – 10480 Sft, First floor- 10480 Sft., Second Floor-10480 Sft, Third Floor- 10489 Sft)


Taking into consideration of above observations, I am to say that the said building is structurally safe under normal weather condition, maintenance and use. This may be treated as safety certificate and it is valid upto March 2023

Yours faithfully,


Superintending Engineer
Kalahandi (R&B) Division.

Memo No. 1897 // Date. 17.3.22 //

Copy to the Executive Engineer, Building(R&B) Sub-Division-II, Bhawanipatna for information and necessary action with reference to his letter No-252 Dtd. 09.03.2022.


Superintending Engineer
Kalahandi (R&B) Division.